



OFFICE OF PROCUREMENT SERVICES
315 WEST MAIN STREET, SUITE 441
PO BOX 7800
TAVARES FL 32778-7800

PHONE: (352) 343-9839
FAX: (352) 343-9473

www.lakegovernment.com

ADDENDUM NO. 2

Date: November 10, 2015

Invitation to Bid (ITB) 16-0205

Re-Roofing of the Agricultural Center Building

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid response. Acknowledgement may be confirmed either by inclusion of a signed copy of this addendum with the initial bid response, or by completion and return of the addendum acknowledgement section of the solicitation. Failure to acknowledge each addendum may prevent the bid from being considered for award.

This addendum DOES NOT change the date for receipt of bids or proposals.

The purpose of this addendum is to provide a confirming response to several vendor inquiries regarding the re-roof process to be utilized. The various questions and response are stated below:

Inquiry: In review of the installation documents the top coat is a flood coat of tar & gravel. We would like to submit an option of a torch applied cap sheet in lieu of the tar & gravel. There would be a cost saving to the owner. I'm working with Johns Manville to prepare the documents if you will review my request & can meet the warranty requirements.

Inquiry: Will they entertain other options such as a granulated torch applied cap sheet in lieu of the coal tar?

Inquiry: We are reviewing the specs for this job and noticed a cold process coal tar flood coat with gravel is specked for this job. I am wondering if this is in fact the system you will be going with? Will you entertain other options such as a granulated cap sheet in lieu of coal tar with gravel? This will determine are ability to bid or not bid this project.

Response to all the above: The departmental representative advises “No, we would not want to substitute with a torch down. Coal tar was chosen because of the specific conditions on this roof.” The type of roofing to be installed will be as currently specified in the Invitation to Bid.

Acknowledgement of Addendum:

Firm Name: _____ Date: _____

Signature: _____ Title: _____

Typed/Printed Name: _ _____